

Notified body No. 1121

Certificate of constancy of performance

1121-CPR-BC5005

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

“Loke, Loke DB, Loke Baffle and Loke Hygiene, Balder and Eira”

Intended use: Ceiling tile

Product Performance

Harmonized technical specification - EN 13964: 2014			
Essential characteristics	Performance	Requirement clauses in EN 13964	Report reference
Reaction to fire	A2-s1, d0	4.4.2.1	Classification report: WF 372358
Resistance to fire	NPD	4.4.1	N/A
Release of asbestos	No content	4.5.1	Manufacturers declaration
Release of formaldehyde	E1	4.5.2	Manufacturers declaration
Shatter properties (safe breakage)	NPD	4.3.6 and 4.6.1	N/A
Flexural tensile strength	NPD	4.6.2	N/A
Load bearing capacity - Tolerances and dimensions	NPD	4.3.2, 4.3.3 and 4.3.4	N/A
Electrical safety	NPD	4.6.3	N/A
Direct airborne sound insulation	NPD	4.7.3	N/A
Sound absorption	NPD	4.7.2	N/A
Thermal conductivity	NPD	4.10	N/A
Durability	NPD	4.8	N/A

NPD – No Performance Determined.

Product Specification (See Page 3 and 4)

Certificate of constancy of performance

1121-CPR-BC5005

Produced by

Norsk Akustikksenter AS

Djupadalskroken 26

4046 Hafrsfjord

Norway

and produced in the manufacturing plant

J/045

This is coded format and the information is held by the Notified Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 13964: 2014

under system 1 of AVCP are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on **08/11/16** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Paul Duggan

Certification Manager

Exova (UK) Limited trading as Warrington Certification,
Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK